



C E R T I F I C A T E

Certificate No. 11-PPV-0007610/02-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL

**DG6M60
(Tested Type)**

<u>Tested Type</u>	<u>Cell Number</u>	<u>Cell Size</u>	<u>Cell Technology</u>	<u>Power [W]</u>
DG6M60/230	60	156*156 mm	POLY	223-231

**Types extended for similarity* with POLY Cell Technology without need of re-testing
(according to IECCE "Retesting guideline"):**

<u>Type</u>	<u>Cell Number</u>	<u>Cell Size</u>	<u>Power [W]</u>
DG6M60/235*	60	156*156 mm	232-236
DG6M60/240*	60	156*156 mm	237-241

MANUFACTURING & LICENSE HOLDER

D.G. ENERGY s.r.l.

C.da Gidora Zona Industriale 87040 Luzzi (CS)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF

IEC 61215 : 2005

Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval
&

EN 61730-1 / EN 61730-2 : 2007

Photovoltaic (PV) module safety qualification

To be used in plants at a total voltage up to: 1000 Vdc (application Class A)

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY

EA ACCREDITED LABORATORY N. 0085

REPORT No. TIC-M1.11.FVOL.0189/42402

Expiring date 29.05.2016

(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type DG6M60. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certification is performed on tested model as complete certification and retest performed according to IECCE "Retesting guideline" for similarity with model DG6M72TFL72/265with differences in backsheet/ substrate and frame and/ or mounting structure. The certification is performed on tested model as complete certification. This certificate is for type approval and based on voluntarily product test without Factory Inspection.



DAT-ZE-030/09-00



Am Bonner Bogen 2, D-53227 Bonn, 30.05.2011 Dipl.-Ing. F. Sergizzarea

TÜV INTERCERT Certification Body